

300

HEAVY DUTY AIRFOIL SUPPLY GRILLE



300

Heavy Duty Airfoil Supply Grille

The 300 Heavy Duty Airfoil Supply Grille is well-suited to industrial applications, with individually adjustable blades and wide blade spacing for maximum free area and the ability to spot heat and cool.

*Individually adjustable,
extra-deep blades provide
superior airflow control*



*Large blade spacing
maximizes free area*



Double deflection grille



Optional damper (reverse)

PERFORMANCE

- + Extra-deep (3 in.) airfoil blades add maximum strength and superior control of large air volumes.
- + Individually adjustable or gang operated blades provide flexibility in throw distance and can be used for spot heating or cooling.
- + Large blade spacing maximizes free area for reduced pressure drop and sound generation, and minimizes the effect of dirt loading.

HEAVY DUTY CONSTRUCTION

- + The 300 features a heavy duty, formed steel border and extruded aluminum blades.
- + Friction locking holds the individually adjustable blades in position, even at high airflows.
- + Extruded aluminum pivot mullions are added on units over 24 in. to add rigidity and strength to the blades.

GANG OPERATED BLADES

- + The double deflection grille is available with front or rear gang operated blades to allow for directional control of airflow in remote mounted units. The second set of blades are individually adjustable from the face of the grille for added directional control.
- + A pole-operated lever on the face of the unit facilitates deflection of the ganged blades 45° from either side of center.



TYPICAL APPLICATIONS

The 300 Heavy Duty Airfoil Supply Grille features a solid, durable design for industrial conditions and extra-deep airfoil blades for superior control of large air volumes.

CONSTRUCTION

- + Blade Deflection
 - Single (301)
 - Double (302)
- + Options
 - Gang operated blades (302G)
 - Steel opposed blade damper (VCS3)
 - Heavy duty steel opposed blade Damper (VCS5)

PERFORMANCE DATA

Size	Core Velocity (fpm)	300	400	500	600	700	800	1000	1200	1400	1600	1800	
	Velocity Pressure (in. w.g.)	0.006	0.010	0.016	0.022	0.031	0.040	0.062	0.090	0.122	0.160	0.202	
	Total Pressure	0°	0.011	0.020	0.031	0.045	0.061	0.080	0.125	0.180	0.246	0.321	0.406
	(in. w.g.)	15°	0.014	0.025	0.039	0.056	0.077	0.100	0.156	0.225	0.307	0.401	0.507
		45°	0.031	0.055	0.085	0.123	0.167	0.219	0.341	0.492	0.669	0.874	1.106
Ac = 0.15 ft ² 7 x 4 6 x 5	Flow Rate (cfm)		45	60	75	90	105	120	150	180	210	240	270
	Sound (NC)		-	-	16	21	26	30	36	41	46	50	53
	Throw (ft)	0°		4-6-11	5-8-14	6-9-15	8-11-17	9-13-18	10-14-19	12-15-21	14-17-23	15-18-25	16-19-27
15°			3-5-9	4-6-11	5-8-12	6-9-13	7-10-14	8-11-15	10-12-17	11-13-19	12-14-20	12-15-22	13-16-23
45°			2-3-6	3-4-7	3-5-8	4-6-8	4-6-9	5-7-10	6-8-11	7-8-12	7-9-13	8-10-14	8-10-14
Ac = 0.18 ft ² 8 x 4 7 x 5 6 x 6	Flow Rate (cfm)		54	72	90	108	126	144	180	216	252	288	324
	Sound (NC)		-	-	16	22	26	30	36	42	46	50	53
	Throw (ft)	0°		4-6-12	6-8-15	7-10-17	8-12-18	10-14-20	11-15-21	14-17-23	15-18-26	16-20-28	17-21-30
15°			3-5-10	4-7-12	6-8-13	7-10-15	8-11-16	9-12-17	11-13-19	12-15-21	13-16-22	14-17-24	15-18-25
45°			2-3-6	3-4-7	3-5-8	4-6-9	5-7-10	6-7-10	7-8-12	7-9-13	8-10-14	9-10-15	9-11-16
Ac = 0.22 ft ² 10 x 4 8 x 5 7 x 6	Flow Rate (cfm)		66	88	110	132	154	176	220	264	308	352	396
	Sound (NC)		-	-	17	22	26	30	37	42	46	50	54
	Throw (ft)	0°		4-7-14	6-9-16	8-11-18	9-14-20	11-15-22	12-16-23	15-18-26	16-20-28	18-22-31	19-23-33
15°			3-6-11	5-7-13	6-9-15	7-11-16	9-12-17	10-13-19	12-15-21	13-16-23	14-17-25	15-19-26	16-20-28
45°			2-3-7	3-5-8	4-6-9	5-7-10	5-8-11	6-8-12	7-9-13	8-10-14	9-11-15	9-12-16	10-12-17
Ac = 0.26 ft ² 12 x 4 10 x 5 8 x 6	Flow Rate (cfm)		78	104	130	156	182	208	260	312	364	416	468
	Sound (NC)		-	-	17	22	27	31	37	42	47	51	54
	Throw (ft)	0°		5-7-15	7-10-18	8-12-20	10-15-22	12-17-24	13-18-25	16-20-28	18-22-31	19-24-33	21-25-36
15°			4-6-12	5-8-14	7-10-16	8-12-17	9-13-19	11-14-20	13-16-23	14-17-25	15-19-27	16-20-28	17-21-30
45°			2-4-7	3-5-9	4-6-10	5-7-11	6-8-12	7-9-13	8-10-14	9-11-15	10-12-17	10-13-18	11-13-19
Ac = 0.30 ft ² 14 x 4	Flow Rate (cfm)		90	120	150	180	210	240	300	360	420	480	540
	Sound (NC)		-	-	17	22	27	31	37	43	47	51	54
	Throw (ft)	0°		5-8-16	7-11-19	9-13-21	11-16-23	13-18-25	14-19-27	17-21-30	19-23-33	21-25-36	22-27-38
15°			4-6-13	6-9-15	7-11-17	9-13-19	10-14-20	11-15-22	14-17-24	15-19-27	17-20-29	18-22-31	19-23-32
45°			2-4-8	4-5-10	4-7-11	5-8-12	6-9-13	7-10-14	9-11-15	10-12-17	10-13-18	11-14-19	12-14-20
Ac = 0.34 ft ² 16 x 4 12 x 5 10 x 6	Flow Rate (cfm)		102	136	170	204	238	272	340	408	476	544	612
	Sound (NC)		-	-	17	23	27	31	37	43	47	51	54
	Throw (ft)	0°		5-9-17	8-11-20	10-14-23	11-17-25	13-19-27	15-20-29	19-23-32	20-25-35	22-27-38	24-29-41
15°			4-7-14	6-9-16	8-11-18	9-14-20	11-15-22	12-16-23	15-18-26	16-20-28	18-22-30	19-23-33	20-24-35
45°			3-4-9	4-6-10	5-7-11	6-9-12	7-10-13	8-10-14	9-11-16	10-12-18	11-13-19	12-14-20	12-15-22
Ac = 0.39 ft ² 18 x 4 14 x 5 12 x 6 8 x 8	Flow Rate (cfm)		117	156	195	234	273	312	390	468	546	624	702
	Sound (NC)		-	-	18	23	27	31	38	43	47	51	55
	Throw (ft)	0°		6-9-18	8-12-22	10-15-24	12-18-27	14-20-29	16-22-31	20-24-34	22-27-38	24-29-41	25-31-44
15°			5-7-15	7-10-17	8-12-20	10-15-21	11-16-23	13-17-25	16-20-28	17-21-30	19-23-33	20-25-35	21-26-37
45°			3-5-9	4-6-11	5-8-12	6-9-13	7-10-14	8-11-15	10-12-17	11-13-19	12-14-20	13-15-22	13-16-23

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70-2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Air flow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle) and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.
6. The NC values are based on a room absorption of 10dB, re 10⁻¹² watts with a single register set at 0° deflection. For deflection settings of 15° and 45°, increase the listed sound levels by 1 and 12 respectively.
7. Blanks "-" indicate an NC level below 15.
8. **Deflection**
The listed deflection settings refer to horizontal deflection. For a 15° upward deflection, use the room throw rating for a 0° setting and the total pressure for a 15° horizontal setting.
The performance tables are based on units with an opposed blade damper.

Corrections for grilles without dampers

	0°	15°	45°
NC	-13	-13	-5
Total Pressure	x .82	x .83	x .93

PERFORMANCE DATA

Size	Core Velocity (fpm)	300	400	500	600	700	800	1000	1200	1400	1600	1800
	Velocity Pressure (in. w.g.)	0.006	0.01	0.016	0.022	0.031	0.04	0.062	0.09	0.122	0.16	0.202
	Total Pressure (in. w.g.)	0.011	0.02	0.031	0.045	0.061	0.08	0.125	0.18	0.246	0.321	0.406
	0°	0.014	0.025	0.039	0.056	0.077	0.1	0.156	0.225	0.307	0.401	0.507
	15°	0.031	0.055	0.085	0.123	0.167	0.219	0.341	0.492	0.669	0.874	1.106
Ac = 0.46 ft ² 20 x 4 16 x 5 14 x 6 10 x 8	Flow Rate (cfm)	138	184	230	276	322	368	460	552	644	736	828
	Sound (NC)	-	-	18	23	28	32	38	43	48	52	55
	Throw (ft)	0°	06-10-20	9-13-24	11-17-26	13-20-29	16-22-31	18-24-34	22-26-37	24-29-41	26-31-44	27-34-47
Ac = 0.52 ft ² 24 x 4 18 x 5 16 x 6	Flow Rate (cfm)	156	208	260	312	364	416	520	624	728	832	936
	Sound (NC)	-	-	18	23	28	32	38	43	48	52	55
	Throw (ft)	0°	07-11-21	9-14-25	12-18-28	14-21-31	16-24-33	19-25-36	23-28-40	25-31-44	27-33-47	29-36-50
Ac = 0.60 ft ² 28 x 4 20 x 5 18 x 6 12 x 8 10 x 10	Flow Rate (cfm)	180	240	300	360	420	480	600	720	840	960	1080
	Sound (NC)	-	-	18	24	28	32	38	44	48	52	55
	Throw (ft)	0°	07-11-23	10-15-27	13-19-30	15-23-33	18-25-36	20-27-38	25-30-43	27-33-47	29-36-51	31-38-54
Ac = 0.69 ft ² 30 x 4 24 x 5 20 x 6 14 x 8 12 x 10	Flow Rate (cfm)	207	276	345	414	483	552	690	828	966	1104	1242
	Sound (NC)	-	-	19	24	28	32	39	44	48	52	56
	Throw (ft)	0°	08-12-24	11-16-29	14-20-32	16-24-36	19-27-38	22-29-41	26-32-46	29-36-50	31-38-54	34-41-58
Ac = 0.81 ft ² 36 x 4 28 x 5 22 x 6 16 x 8 14 x 10	Flow Rate (cfm)	243	324	405	486	567	648	810	972	1134	1296	1458
	Sound (NC)	-	-	19	24	29	32	39	44	49	52	56
	Throw (ft)	0°	8-13-26	12-18-31	15-22-35	18-26-39	21-29-42	24-31-44	29-35-50	31-39-54	34-42-59	36-44-63
Ac = 0.90 ft ² 40 x 4 18 x 8 30 x 5 16 x 10 26 x 6 12 x 12	Flow Rate (cfm)	270	360	450	540	630	720	900	1080	1260	1440	1620
	Sound (NC)	-	-	19	24	29	33	39	44	49	53	56
	Throw (ft)	0°	9-14-28	12-19-33	15-23-37	19-28-41	22-31-44	25-33-47	30-37-52	33-41-57	36-44-62	38-47-66
Ac = 1.07 ft ² 48 x 4 36 x 5 30 x 6 18 x 10 14 x 12	Flow Rate (cfm)	321	428	535	642	749	856	1070	1284	1498	1712	1926
	Sound (NC)	-	-	19	25	29	33	39	45	49	53	56
	Throw (ft)	0°	9-15-30	14-20-36	17-25-40	20-30-44	24-34-48	27-36-51	33-40-57	36-44-63	39-48-68	42-51-72
	15°	07-12-24	11-16-29	14-20-32	16-24-35	19-27-38	22-29-41	26-32-46	29-35-50	31-38-54	33-41-58	35-43-61
	45°	05-08-15	07-10-18	8-13-20	10-15-22	12-17-24	14-18-26	16-20-29	18-22-31	20-24-34	21-26-36	22-27-38

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70-2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Air flow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle) and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.
6. The NC values are based on a room absorption of 10dB, re 10⁻¹² watts with a single register set at 0° deflection. For deflection settings of 15° and 45°, increase the listed sound levels by 1 and 12 respectively.
7. Blanks "-" indicate an NC level below 15.
8. **Deflection**
The listed deflection settings refer to horizontal deflection. For a 15° upward deflection, use the room throw rating for a 0° setting and the total pressure for a 15° horizontal setting.
The performance tables are based on units with an opposed blade damper.

Corrections for grilles without dampers

	0°	15°	45°
NC	-13	-13	-5
Total Pressure	x .82	x .83	x .93

PERFORMANCE DATA

Size	Core Velocity (fpm)	300	400	500	600	700	800	1000	1200	1400	1600	1800	
	Velocity Pressure (in. w.g.)	0.006	0.01	0.016	0.022	0.031	0.04	0.062	0.09	0.122	0.16	0.202	
	Total Pressure (in. w.g.)	0°	0.011	0.02	0.031	0.045	0.061	0.08	0.125	0.18	0.246	0.321	0.406
		15°	0.014	0.025	0.039	0.056	0.077	0.1	0.156	0.225	0.307	0.401	0.507
		45°	0.031	0.055	0.085	0.123	0.167	0.219	0.341	0.492	0.669	0.874	1.106
Ac = 1.18 ft² 34 x 6 24 x 8 20 x 10 16 x 12 14 x 14	Flow Rate (cfm)		354	472	590	708	826	944	1180	1416	1652	1888	2124
	Sound (NC)		-	-	20	25	29	33	40	45	49	53	57
	Throw (ft)	0°	10-16-32	14-21-38	18-27-42	21-32-46	25-35-50	28-38-54	35-42-60	38-46-66	41-50-71	44-54-76	46-57-80
		15°	8-13-26	11-17-30	14-21-34	17-26-37	20-28-40	23-30-43	28-34-48	30-37-53	33-40-57	35-43-61	37-46-64
		45°	05-08-16	07-11-19	9-13-21	11-16-23	12-18-25	14-19-27	17-21-30	19-23-33	20-25-35	22-27-38	23-28-40
Ac = 1.34 ft² 60 x 4 48 x 5 36 x 6 18 x 12 16 x 14	Flow Rate (cfm)		402	536	670	804	938	1072	1340	1608	1876	2144	2412
	Sound (NC)		-	-	20	25	29	33	40	45	49	53	57
	Throw (ft)	0°	10-17-34	15-23-40	19-28-45	23-34-50	26-38-53	30-40-57	37-45-64	40-50-70	44-53-76	47-57-81	50-61-86
		15°	8-14-27	12-18-32	15-23-36	18-27-40	21-30-43	24-32-46	30-36-51	32-40-56	35-43-61	37-46-65	40-49-69
		45°	05-09-17	08-11-20	9-14-23	11-17-25	13-19-27	15-20-29	18-23-32	20-25-35	22-27-38	23-29-40	25-30-43
Ac = 1.60 ft² 72 x 4 22 x 12 30 x 8 18 x 14 24 x 10 16 x 16	Flow Rate (cfm)		480	640	800	960	1120	1280	1600	1920	2240	2560	2880
	Sound (NC)		-	-	20	25	30	34	40	45	50	54	57
	Throw (ft)	0°	11-19-37	17-25-44	21-31-49	25-37-54	29-41-58	33-44-62	40-49-70	44-54-77	48-58-83	51-62-88	54-66-94
		15°	9-15-30	13-20-35	17-25-40	20-30-43	23-33-47	26-35-50	32-40-56	35-43-61	38-47-66	41-50-71	43-53-75
		45°	06-09-19	08-12-22	10-15-25	12-19-27	14-21-29	17-22-31	20-25-35	22-27-38	24-29-41	26-31-44	27-33-47
Ac = 1.80 ft² 60 x 5 30 x 10 48 x 6 24 x 12 36 x 8 20 x 14	Flow Rate (cfm)		540	720	900	1080	1260	1440	1800	2160	2520	2880	3240
	Sound (NC)		-	-	20	26	30	34	40	46	50	54	57
	Throw (ft)	0°	12-20-39	18-26-47	22-33-52	26-39-57	31-44-62	35-47-66	43-52-74	47-57-81	51-62-88	54-66-94	57-70-99
		15°	10-16-32	14-21-37	18-26-42	21-32-46	25-35-50	28-37-53	34-42-59	37-46-65	40-50-70	43-53-75	46-56-80
		45°	06-10-20	9-13-23	11-16-26	13-20-29	15-22-31	18-23-33	21-26-37	23-29-41	25-31-44	27-33-47	29-35-50
Ac = 2.08 ft² 72 x 5 30 x 12 60 x 6 24 x 14 40 x 8 20 x 16 35 x 10 18 x 18	Flow Rate (cfm)		624	832	1040	1248	1456	1664	2080	2496	2912	3328	3744
	Sound (NC)		-	-	20	26	30	34	41	46	50	54	57
	Throw (ft)	0°	13-21-42	19-28-50	24-35-56	28-42-62	33-47-67	38-50-71	46-56-80	50-62-87	54-67-94	58-71-101	62-76-107
		15°	10-17-34	15-23-40	19-28-45	23-34-49	26-38-53	30-40-57	37-45-64	40-49-70	44-53-75	47-57-81	49-60-85
		45°	07-11-21	9-14-25	12-18-28	14-21-31	16-24-33	19-25-36	23-28-40	25-31-44	27-33-47	29-36-50	31-38-53
Ac = 2.45 ft² 72 x 6 24 x 16 48 x 8 20 x 18 32 x 12 20 x 20 26 x 14	Flow Rate (cfm)		735	980	1225	1470	1715	1960	2450	2940	3430	3920	4410
	Sound (NC)		-	-	21	26	30	34	41	46	50	54	58
	Throw (ft)	0°	14-23-46	20-31-55	26-38-61	31-46-67	36-51-72	41-55-77	50-61-86	55-67-95	59-72-102	63-77-109	67-82-116
		15°	11-18-37	16-25-44	20-31-49	25-37-54	29-41-58	33-44-62	40-49-69	44-54-76	47-58-82	51-62-87	54-66-93
		45°	07-12-23	10-15-27	13-19-31	15-23-33	18-26-36	20-27-39	25-31-43	27-33-47	30-36-51	32-39-55	33-41-58
Ac = 2.78 ft² 36 x 12 30 x 14 26 x 16 24 x 18 22 x 20	Flow Rate (cfm)		834	1112	1390	1668	1946	2224	2780	3336	3892	4448	5004
	Sound (NC)		-	-	21	26	31	35	41	46	51	55	58
	Throw (ft)	0°	15-25-49	22-33-58	27-41-65	33-49-71	38-54-77	44-58-82	53-65-92	58-71-101	63-77-109	67-82-116	71-87-124
		15°	12-20-39	17-26-47	22-33-52	26-39-57	31-44-62	35-47-66	43-52-74	47-57-81	50-62-87	54-66-93	57-70-99
		45°	08-12-25	11-16-29	14-20-33	16-25-36	19-27-39	22-29-41	27-33-46	29-36-50	31-39-54	34-41-58	36-44-62

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70-2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Air flow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle) and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.

6. The NC values are based on a room absorption of 10dB, re 10⁻¹² watts with a single register set at 0° deflection. For deflection settings of 15° and 45°, increase the listed sound levels by 1 and 12 respectively.
7. Blanks "-" indicate an NC level below 15.
8. **Deflection**
The listed deflection settings refer to horizontal deflection. For a 15° upward deflection, use the room throw rating for a 0° setting and the total pressure for a 15° horizontal setting.
The performance tables are based on units with an opposed blade damper.

Corrections for grilles without dampers

	0°	15°	45°
NC	-13	-13	-5
Total Pressure	x .82	x .83	x .93

PERFORMANCE DATA

Size	Core Velocity (fpm)	300	400	500	600	700	800	1000	1200	1400	1600	1800	
	Velocity Pressure (in. w.g.)	0.006	0.01	0.016	0.022	0.031	0.04	0.062	0.09	0.122	0.16	0.202	
	Total Pressure (in. w.g.)	0°	0.011	0.02	0.031	0.045	0.061	0.08	0.125	0.18	0.246	0.321	0.406
		15°	0.014	0.025	0.039	0.056	0.077	0.1	0.156	0.225	0.307	0.401	0.507
		45°	0.031	0.055	0.085	0.123	0.167	0.219	0.341	0.492	0.669	0.874	1.106
Ac = 3.11 ft ² 60 x 8 36 x 14 48 x 10 30 x 16 40 x 12 26 x 18	Flow Rate (cfm)		933	1244	1555	1866	2177	2488	3110	3732	4354	4976	5598
	Sound (NC)		-	-	21	26	31	35	41	46	51	55	58
	Throw (ft)	0°	16-26-52	23-35-62	29-43-69	35-52-75	40-58-81	46-62-87	56-69-97	62-75-107	67-81-115	71-87-123	75-92-131
		15°	13-21-41	18-28-49	23-35-55	28-41-60	32-46-65	37-49-70	45-55-78	49-60-85	53-65-92	57-70-99	60-74-105
		45°	8-13-26	12-17-31	14-22-34	17-26-38	20-29-41	23-31-44	28-34-49	31-38-53	33-41-58	36-44-62	38-46-65
Ac=361 ft ² 72 x 8 36 x 16 60 x 10 30 x 18 48 x 12 28 x 20	Flow Rate (cfm)		1083	1444	1805	2166	2527	2888	3610	4332	5054	5776	6498
	Sound (NC)		-	-	21	27	31	35	41	47	51	55	58
	Throw (ft)	0°	17-28-56	25-37-66	31-47-74	37-56-81	43-62-88	50-66-94	61-74-105	66-81-115	72-88-124	77-94-133	81-100-141
		15°	14-22-45	20-30-53	25-37-59	30-45-65	35-50-70	40-53-75	48-59-84	53-65-92	57-70-99	61-75-106	65-80-113
		45°	9-14-28	12-19-33	16-23-37	19-28-41	22-31-44	25-33-47	30-37-52	33-41-57	36-44-62	38-47-66	41-50-70
Ac = 4.29 ft ² 48 x 14 36 x 18 32 x 20 28 x 24	Flow Rate (cfm)		1287	1716	2145	2574	3003	3432	4290	5148	6006	6864	7722
	Sound (NC)		-	15	22	27	31	35	42	47	51	55	59
	Throw (ft)	0°	19-30-61	27-41-72	34-51-81	41-61-89	47-68-96	54-72-102	66-81-114	72-89-125	78-96-135	84-102-145	89-109-153
		15°	15-24-49	22-32-58	27-41-65	32-49-71	38-54-77	43-58-82	53-65-92	58-71-100	63-77-108	67-82-116	71-87-123
		45°	9-15-30	14-20-36	17-25-40	20-30-44	24-34-48	27-36-51	33-40-57	36-44-63	39-48-68	42-51-72	44-54-77
Ac = 4.65 ft ² 72 x 10 48 x 16 36 x 20 30 x 24	Flow Rate (cfm)		1395	1860	2325	2790	3255	3720	4650	5580	6510	7440	8370
	Sound (NC)		-	15	22	27	32	35	42	47	52	55	59
	Throw (ft)	0°	20-32-63	28-42-75	35-53-84	42-63-92	49-70-100	56-75-107	69-84-119	75-92-130	81-100-141	87-107-151	92-113-160
		15°	16-25-51	23-34-60	28-42-67	34-51-74	39-56-80	45-60-85	55-67-95	60-74-104	65-80-113	70-85-121	74-90-128
		45°	10-16-32	14-21-38	18-26-42	21-32-46	25-35-50	28-38-53	34-42-60	38-46-65	41-50-70	43-53-75	46-56-80
Ac = 5.58 ft ² 72 x 12 60 x 14 48 x 18 36 x 24	Flow Rate (cfm)		1674	2232	2790	3348	3906	4464	5580	6696	7812	8928	10044
	Sound (NC)		-	16	22	27	32	36	42	47	52	56	59
	Throw (ft)	0°	21-35-69	31-46-83	39-58-92	46-69-101	54-77-109	62-83-117	75-92-130	83-101-143	89-109-154	95-117-165	101-124-175
		15°	17-28-56	25-37-66	31-46-74	37-56-81	43-62-87	49-66-93	60-74-104	66-81-114	71-87-123	76-93-132	81-99-140
		45°	11-17-35	15-23-41	19-29-46	23-35-51	27-39-55	31-41-58	38-46-65	41-51-71	45-55-77	48-58-83	51-62-88
Ac = 6.25 ft ² 72 x 14 60 x 16 48 x 20 30 x 30	Flow Rate (cfm)		1875	2500	3125	3750	4375	5000	6250	7500	8750	10000	11250
	Sound (NC)		-	16	22	28	32	36	42	48	52	56	59
	Throw (ft)	0°	23-37-74	33-49-87	41-61-98	49-74-107	57-82-116	65-87-124	80-98-138	87-107-151	94-116-163	101-124-175	107-131-185
		15°	18-29-59	26-39-70	33-49-78	39-59-86	46-65-92	52-70-99	64-78-110	70-86-121	75-92-131	81-99-140	86-105-148
		45°	11-18-37	16-25-44	20-31-49	25-37-53	29-41-58	33-44-62	40-49-69	44-53-76	47-58-82	50-62-87	53-65-93

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70-2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Air flow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle) and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.
6. The NC values are based on a room absorption of 10dB, re 10⁻¹² watts with a single register set at 0° deflection. For deflection settings of 15° and 45°, increase the listed sound levels by 1 and 12 respectively.
7. Blanks "-" indicate an NC level below 15.
8. **Deflection**
The listed deflection settings refer to horizontal deflection. For a 15° upward deflection, use the room throw rating for a 0° setting and the total pressure for a 15° horizontal setting.
The performance tables are based on units with an opposed blade damper.

Corrections for grilles without dampers

	0°	15°	45°
NC	-13	-13	-5
Total Pressure	x .82	x .83	x .93



Product Improvement is a continuing endeavour at Price. Therefore, specifications are subject to change without notice. Consult your Price Sales Representative for current specifications or more detailed information. Not all products may be available in all geographic areas. All goods described in this document are warranted as described in the Limited Warranty shown at priceindustries.com. The complete Price product catalog can be viewed online at priceindustries.com.