

PERFORMANCE DATA

PDF/PDFE - 12 in. x 12 in.

Inlet Size	Neck Velocity (fpm)	300	400	500	600	700	800	900	1000	1200	1400	
	Velocity Pressure (in. w.g.)	.006	.010	.016	.022	.031	.040	.050	.062	.090	.122	
6 Ø	Total Pressure (in. w.g.)	.012	.021	.033	.047	.064	.084	.106	.131	.189	.257	
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274	
	Sound (NC)	-	-	-	19	24	28	32	35	41	46	
	Throw (ft.)	4 Way	0-1-4	1-2-6	1-3-7	2-4-8	3-5-9	4-6-10	4-7-10	5-7-11	6-8-12	7-9-13
		3 Way	1-1-5	1-2-7	2-4-9	2-5-10	3-6-11	4-7-11	5-8-12	6-9-13	7-10-14	8-11-15
2 Way		1-2-7	1-3-10	2-5-12	3-7-13	4-8-14	6-10-15	7-11-16	8-12-17	10-13-19	11-14-20	
1 Way		1-2-9	2-4-12	3-6-15	4-9-17	5-10-18	7-12-19	9-13-20	10-15-21	12-17-23	14-18-25	
6 x 6	Total Pressure (in. w.g.)	.013	.024	.037	.054	.073	.096	.121	.150	.215	.293	
	Flow Rate (cfm)	75	100	125	150	175	200	225	250	300	350	
	Sound (NC)	-	-	17	22	27	31	35	38	44	48	
	Throw (ft.)	4 Way	1-1-5	1-2-7	2-4-9	2-5-9	3-6-10	4-7-11	5-8-11	6-9-12	7-9-13	8-10-14
		3 Way	1-2-6	1-3-8	2-5-10	3-6-11	4-7-12	5-8-13	6-9-14	7-10-14	8-11-16	10-12-17
2 Way		1-2-8	2-4-11	3-6-14	4-8-15	5-10-16	7-11-17	8-13-18	9-14-19	11-15-21	13-16-23	
1 Way		1-3-11	2-5-14	3-8-17	5-11-19	7-12-20	9-14-22	11-16-23	12-17-24	14-19-26	16-20-29	

PDF/PDFE - 12 in. x 24 in.

Inlet Size	Neck Velocity (fpm)	300	400	500	600	700	800	900	1000	1200	1400	
	Velocity Pressure (in. w.g.)	.006	.010	.016	.022	.031	.040	.050	.062	.090	.122	
6 Ø	Total Pressure (in. w.g.)	.012	.021	.033	.047	.064	.084	.106	.131	.189	.257	
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274	
	Sound (NC)	-	-	-	19	24	28	32	35	41	46	
	Throw (ft.)	4 Way	0-1-4	1-2-6	1-3-7	2-4-8	3-5-9	4-6-10	4-7-10	5-7-11	6-8-12	7-9-13
		3 Way	1-1-5	1-2-7	2-4-9	2-5-10	3-6-11	4-7-11	5-8-12	6-9-13	7-10-14	8-11-15
2 Way		1-2-7	1-3-10	2-5-12	3-7-13	4-8-14	6-10-15	7-11-16	8-12-17	10-13-19	11-14-20	
1 Way		1-2-9	2-4-12	3-6-15	4-9-17	5-10-18	7-12-19	9-13-20	10-15-21	12-17-23	14-18-25	
6 x 6	Total Pressure (in. w.g.)	.013	.024	.037	.054	.073	.096	.121	.150	.215	.293	
	Flow Rate (cfm)	75	100	125	150	175	200	225	250	300	350	
	Sound (NC)	-	-	17	22	27	31	35	38	44	48	
	Throw (ft.)	4 Way	1-1-5	1-2-7	2-4-9	2-5-9	3-6-10	4-7-11	5-8-11	6-9-12	7-9-13	8-10-14
		3 Way	1-2-6	1-3-8	2-5-10	3-6-11	4-7-12	5-8-13	6-9-14	7-10-14	8-11-16	10-12-17
2 Way		1-2-8	2-4-11	3-6-14	4-8-15	5-10-16	7-11-17	8-13-18	9-14-19	11-15-21	13-16-23	
1 Way		1-3-11	2-5-14	3-8-17	5-11-19	7-12-20	9-14-22	11-16-23	12-17-24	14-19-26	16-20-29	
6 x 18	Total Pressure (in. w.g.)	.026	.047	.073	.105	.144	.188	.237	.293	.422	.574	
	Flow Rate (cfm)	225	300	375	450	525	600	675	750	900	1050	
	Sound (NC)	-	22	29	35	40	44	47	51	56	61	
	Throw (ft.)	4 Way	2-5-11	4-8-13	6-9-15	8-11-16	9-12-17	10-13-19	11-14-20	12-15-21	13-16-23	14-17-25
		3 Way	2-6-14	4-9-16	7-11-18	9-14-19	11-15-21	12-16-22	14-17-24	14-18-25	16-19-27	17-21-30
2 Way		3-7-18	6-12-21	9-15-24	12-18-26	14-20-28	16-21-30	18-22-32	19-24-33	21-26-37	23-28-40	
1 Way		4-9-23	7-15-26	11-19-30	15-23-32	18-25-35	20-26-37	23-28-40	24-30-42	26-32-46	29-35-49	

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Airflow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle), and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.
6. NC, sound pressure levels, are based on room absorption of 10 dB re 10⁻¹² Watts and one diffuser.
7. Blanks (-) indicate an NC level below 15.
8. Data does not include effects of ceiling radiation damper (PDF-FR, PDFE-FR).

PERFORMANCE DATA

PDF/PDFE - 16 in. x 16 in.

Inlet Size	Neck Velocity (fpm) Velocity Pressure (in. w.g.)	300 .006	400 .010	500 .016	600 .022	700 .031	800 .040	900 .050	1000 .062	1200 .090	1400 .122
6 Ø	Total Pressure (in. w.g.)	.012	.021	.033	.047	.064	.084	.106	.131	.189	.257
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	19	24	28	32	35	41	46
	Throw (ft.)	0-1-4	1-2-6	1-3-7	2-4-8	3-5-9	4-6-10	4-7-10	5-7-11	6-8-12	7-9-13
	1 Way	1-1-5	1-2-7	2-4-9	2-5-10	3-6-11	4-7-11	5-8-12	6-9-13	7-10-14	8-11-15
6 x 6	Total Pressure (in. w.g.)	.013	.024	.037	.054	.073	.096	.121	.150	.215	.293
	Flow Rate (cfm)	75	100	125	150	175	200	225	250	300	350
	Sound (NC)	-	-	17	22	27	31	35	38	44	48
	Throw (ft.)	1-1-5	1-2-7	2-4-9	2-5-9	3-6-10	4-7-11	5-8-11	6-9-12	7-9-13	8-10-14
	1 Way	1-2-6	1-3-8	2-5-10	3-6-11	4-7-12	5-8-13	6-9-14	7-10-14	8-11-16	10-12-17
8 Ø	Total Pressure (in. w.g.)	.017	.029	.046	.066	.090	.118	.149	.184	.265	.360
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	21	26	31	35	39	42	48	52
	Throw (ft.)	1-2-7	2-3-9	2-5-10	3-7-11	5-8-12	6-9-13	7-10-14	7-10-14	9-11-16	10-12-17
	1 Way	1-2-8	2-4-11	3-7-12	4-8-13	6-9-14	7-11-15	8-11-16	9-12-17	11-13-19	12-14-20
8 x 8	Total Pressure (in. w.g.)	.019	.034	.053	.076	.104	.136	.172	.212	.305	.415
	Flow Rate (cfm)	133	178	222	266	311	355	400	444	533	622
	Sound (NC)	-	16	23	29	34	38	41	45	50	55
	Throw (ft.)	1-3-8	2-5-10	3-6-11	5-8-12	6-9-13	7-10-14	8-11-15	9-11-16	10-12-18	11-13-19
	1 Way	1-3-9	2-5-12	4-8-14	5-9-15	7-11-16	8-12-17	9-13-18	10-14-19	12-15-21	13-16-23
10 Ø	Total Pressure (in. w.g.)	.022	.039	.061	.088	.119	.156	.197	.243	.350	.477
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	19	26	31	36	40	44	47	53	57
	Throw (ft.)	1-3-10	3-6-11	4-7-13	6-9-14	7-10-15	8-11-16	9-12-17	10-13-18	11-14-20	12-15-21
	1 Way	2-4-11	3-7-14	5-9-15	7-11-17	8-13-18	10-14-19	11-14-20	12-15-21	14-17-23	15-18-25

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Airflow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle), and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.
6. NC, sound pressure levels, are based on room absorption of 10 dB re 10⁻¹² Watts and one diffuser.
7. Blanks (-) indicate an NC level below 15.
8. Data does not include effects of ceiling radiation damper (PDF-FR, PDFE-FR).

PERFORMANCE DATA

PDF/PDFE - 20 in. x 20 in.

Inlet Size	Neck Velocity (fpm)	300	400	500	600	700	800	900	1000	1200	1400	
	Velocity Pressure (in. w.g.)	.006	.010	.016	.022	.031	.040	.050	.062	.090	.122	
6 Ø	Total Pressure (in. w.g.)	.012	.021	.033	.047	.064	.084	.106	.131	.189	.257	
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274	
	Sound (NC)	-	-	-	19	24	28	32	35	41	46	
	Throw (ft.)	4 Way	0-1-4	1-2-6	1-3-7	2-4-8	3-5-9	4-6-10	4-7-10	5-7-11	6-8-12	7-9-13
	3 Way	1-1-5	1-2-7	2-4-9	2-5-10	3-6-11	4-7-11	5-8-12	6-9-13	7-10-14	8-11-15	
2 Way	1-2-7	1-3-10	2-5-12	3-7-13	4-8-14	6-10-15	7-11-16	8-12-17	10-13-19	11-14-20		
1 Way	1-2-9	2-4-12	3-6-15	4-9-17	5-10-18	7-12-19	9-13-20	10-15-21	12-17-23	14-18-25		
6 x 6	Total Pressure (in. w.g.)	.013	.024	.037	.054	.073	.096	.121	.150	.215	.293	
	Flow Rate (cfm)	75	100	125	150	175	200	225	250	300	350	
	Sound (NC)	-	-	17	22	27	31	35	38	44	48	
	Throw (ft.)	4 Way	1-1-5	1-2-7	2-4-9	2-5-9	3-6-10	4-7-11	5-8-11	6-9-12	7-9-13	8-10-14
	3 Way	1-2-6	1-3-8	2-5-10	3-6-11	4-7-12	5-8-13	6-9-14	7-10-14	8-11-16	10-12-17	
2 Way	1-2-8	2-4-11	3-6-14	4-8-15	5-10-16	7-11-17	8-13-18	9-14-19	11-15-21	13-16-23		
1 Way	1-3-11	2-5-14	3-8-17	5-11-19	7-12-20	9-14-22	11-16-23	12-17-24	14-19-26	16-20-29		
8 Ø	Total Pressure (in. w.g.)	.017	.029	.046	.066	.090	.118	.149	.184	.265	.360	
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489	
	Sound (NC)	-	-	21	26	31	35	39	42	48	52	
	Throw (ft.)	4 Way	1-2-7	2-3-9	2-5-10	3-7-11	5-8-12	6-9-13	7-10-14	7-10-14	9-11-16	10-12-17
	3 Way	1-2-8	2-4-11	3-7-12	4-8-13	6-9-14	7-11-15	8-11-16	9-12-17	11-13-19	12-14-20	
2 Way	1-3-11	2-6-14	4-9-16	6-11-18	8-12-19	9-14-20	11-15-22	12-16-23	14-18-25	16-19-27		
1 Way	2-4-13	3-7-18	5-11-20	7-13-22	10-15-24	12-18-26	13-19-27	15-20-29	18-22-31	19-24-34		
8 x 8	Total Pressure (in. w.g.)	.019	.034	.053	.076	.104	.136	.172	.212	.305	.415	
	Flow Rate (cfm)	133	178	222	266	311	355	400	444	533	622	
	Sound (NC)	-	16	23	29	34	38	41	45	50	55	
	Throw (ft.)	4 Way	1-3-8	2-5-10	3-6-11	5-8-12	6-9-13	7-10-14	8-11-15	9-11-16	10-12-18	11-13-19
	3 Way	1-3-9	2-5-12	4-8-14	5-9-15	7-11-16	8-12-17	9-13-18	10-14-19	12-15-21	13-16-23	
2 Way	2-4-12	3-7-16	5-10-18	7-12-20	10-15-22	11-16-23	12-17-24	14-18-26	16-20-28	18-22-30		
1 Way	2-5-16	4-9-20	6-13-23	9-16-25	12-18-27	14-20-29	16-22-31	17-23-32	20-25-35	22-27-38		
10 Ø	Total Pressure (in. w.g.)	.022	.039	.061	.088	.119	.156	.197	.243	.350	.477	
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763	
	Sound (NC)	-	19	26	31	36	40	44	47	53	57	
	Throw (ft.)	4 Way	1-3-9	3-6-11	4-7-13	6-9-14	7-10-15	8-11-16	9-12-17	10-13-18	11-14-20	12-15-21
	3 Way	2-4-11	3-7-14	5-9-15	7-11-17	8-13-18	10-14-19	11-14-20	12-15-21	14-17-23	15-18-25	
2 Way	2-5-14	4-9-18	6-12-20	9-14-22	11-17-24	13-18-26	14-19-27	16-20-29	18-22-31	19-24-34		
1 Way	3-6-18	5-11-23	8-15-25	11-18-28	14-21-30	16-23-32	18-24-34	20-25-36	23-28-39	24-30-42		
10 x 10	Total Pressure (in. w.g.)	.025	.044	.069	.099	.134	.176	.222	.274	.395	.538	
	Flow Rate (cfm)	208	278	347	416	486	555	625	694	833	972	
	Sound (NC)	-	22	28	34	39	43	47	50	55	60	
	Throw (ft.)	4 Way	2-4-11	3-7-13	5-9-14	7-11-16	8-12-17	9-13-18	11-13-19	12-14-20	13-16-22	14-17-24
	3 Way	2-5-13	4-9-15	6-11-17	9-13-19	10-14-20	11-15-22	13-16-23	14-17-24	15-19-26	16-20-29	
2 Way	3-7-17	5-11-20	8-14-23	11-17-25	13-19-27	15-20-29	17-22-31	19-23-32	20-25-35	22-27-38		
1 Way	4-8-21	7-14-25	10-18-28	14-21-31	17-24-34	19-25-36	21-27-38	23-28-40	25-31-44	27-34-48		
12 Ø	Total Pressure (in. w.g.)	.027	.048	.075	.108	.147	.192	.242	.299	.431	.587	
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099	
	Sound (NC)	-	23	30	35	40	44	48	51	57	62	
	Throw (ft.)	4 Way	2-5-12	4-8-14	6-10-15	8-12-17	9-13-18	10-14-19	12-14-20	12-15-21	14-17-23	15-18-25
	3 Way	3-6-14	5-9-16	7-12-18	9-14-20	11-15-21	12-16-23	14-17-24	15-18-26	16-20-28	18-21-30	
2 Way	3-8-19	6-12-22	10-16-24	12-19-27	15-20-29	17-22-31	19-23-32	20-24-34	22-27-38	23-29-41		
1 Way	4-10-23	8-16-27	12-19-30	16-23-33	18-25-36	21-27-38	23-29-41	25-30-43	27-33-47	29-36-51		
14 Ø	Total Pressure (in. w.g.)	.032	.057	.089	.128	.174	.227	.288	.355	.512	.697	
	Flow Rate (cfm)	321	428	535	641	748	855	962	1069	1283	1497	
	Sound (NC)	18	27	33	39	44	48	52	55	60	65	
	Throw (ft.)	4 Way	3-7-14	5-10-16	8-12-18	10-14-19	11-15-21	13-16-22	14-17-24	14-18-25	16-19-27	17-21-30
	3 Way	4-8-16	7-12-19	10-14-21	12-16-23	14-18-25	15-19-27	16-20-28	17-21-30	19-23-33	20-25-35	
2 Way	5-11-22	9-15-25	13-19-28	15-22-31	18-24-33	21-25-36	22-27-38	23-28-40	25-31-44	27-33-47		
1 Way	6-14-27	11-19-32	16-24-35	19-27-39	23-30-42	26-32-45	27-33-47	29-35-50	32-39-55	34-42-59		

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Airflow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle), and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.
6. NC, sound pressure levels, are based on room absorption of 10 dB re 10⁻¹² Watts and one diffuser.
7. Blanks (-) indicate an NC level below 15.
8. Data does not include effects of ceiling radiation damper (PDF-FR, PDFE-FR).

PERFORMANCE DATA

PDF/PDFE - 24 in. x 24 in.

Inlet Size	Neck Velocity (fpm)	300	400	500	600	700	800	900	1000	1200	1400
	Velocity Pressure (in. w.g.)	.006	.010	.016	.022	.031	.040	.050	.062	.090	.122
6 Ø	Total Pressure (in. w.g.)	.009	.016	.026	.037	.050	.066	.083	.103	.148	.202
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	16	21	25	29	32	38	43
	Throw (ft.)	0-0-2	0-1-3	0-1-4	1-2-6	1-2-7	1-3-8	2-3-9	2-4-10	3-6-12	4-7-13
		0-0-2	0-1-3	1-1-5	1-2-7	1-2-9	1-3-10	2-4-11	2-5-13	3-7-14	4-9-15
6 x 6	Total Pressure (in. w.g.)	.010	.018	.029	.042	.057	.074	.093	.115	.166	.226
	Flow Rate (cfm)	75	100	125	150	175	200	225	250	300	350
	Sound (NC)	-	-	-	19	24	28	32	35	41	46
	Throw (ft.)	0-1-4	1-2-6	1-3-8	2-4-9	2-5-10	3-6-11	4-7-11	5-8-12	6-9-13	7-10-14
		0-1-4	1-2-7	1-3-9	2-4-11	3-6-12	3-7-13	4-8-14	5-9-14	7-11-16	9-12-17
8 Ø	Total Pressure (in. w.g.)	.013	.023	.036	.052	.070	.092	.116	.143	.206	.281
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	18	23	28	32	36	39	45	49
	Throw (ft.)	0-1-4	1-2-7	1-3-9	2-4-10	2-5-12	3-7-13	4-8-14	5-9-14	7-10-16	8-12-17
		1-1-5	1-2-8	1-3-10	2-5-12	3-6-14	4-8-15	5-9-16	6-10-17	8-12-19	10-14-20
8 x 8	Total Pressure (in. w.g.)	.015	.026	.041	.059	.081	.106	.134	.165	.238	.324
	Flow Rate (cfm)	133	178	222	266	311	355	400	444	533	622
	Sound (NC)	-	-	20	26	31	35	38	42	47	52
	Throw (ft.)	1-2-7	2-4-10	3-6-11	4-7-12	5-8-13	6-10-14	7-11-15	8-11-16	10-12-18	11-13-19
		1-2-9	2-4-12	3-7-14	4-9-15	6-10-16	8-12-17	9-13-18	10-14-19	12-15-21	13-16-23
10 Ø	Total Pressure (in. w.g.)	.017	.030	.047	.067	.092	.120	.151	.187	.269	.367
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	16	23	28	33	37	41	44	50	54
	Throw (ft.)	1-2-8	2-4-11	2-6-13	4-8-14	5-9-15	6-10-16	8-12-17	9-13-18	10-14-20	12-15-21
		1-2-10	2-4-14	3-7-15	4-9-17	6-11-18	8-12-19	9-14-20	10-15-21	12-17-23	14-18-25
10 x 10	Total Pressure (in. w.g.)	.019	.034	.054	.077	.105	.138	.174	.215	.310	.422
	Flow Rate (cfm)	208	278	347	416	486	555	625	694	833	972
	Sound (NC)	-	19	25	31	36	40	44	47	52	57
	Throw (ft.)	2-4-10	3-7-13	5-9-14	7-10-16	8-12-17	9-13-18	10-13-19	11-14-20	13-16-22	14-17-24
		2-5-12	4-8-15	6-10-17	8-12-19	10-14-20	11-15-22	12-16-23	14-17-24	15-19-26	16-20-29

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Airflow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle), and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.
6. NC, sound pressure levels, are based on room absorption of 10 dB re 10⁻¹² Watts and one diffuser.
7. Blanks (-) indicate an NC level below 15.
8. Data does not include effects of ceiling radiation damper (PDF-FR, PDFE-FR).

PERFORMANCE DATA

PDF/PDFE - 24 in. x 24 in. (continued)

Inlet Size	Neck Velocity (fpm)	300	400	500	600	700	800	900	1000	1200	1400	
	Velocity Pressure (in. w.g.)	.006	.010	.016	.022	.031	.040	.050	.062	.090	.122	
12 Ø	Total Pressure (in. w.g.)	.021	.037	.058	.083	.113	.148	.187	.231	.332	.452	
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099	
	Sound (NC)	-	20	27	32	37	41	45	48	54	59	
	Throw (ft.)	4 Way	2-4-11	3-6-14	4-9-15	6-11-17	8-12-18	9-14-19	11-14-20	12-15-21	14-17-23	15-18-25
	1 Way	2-4-13	3-8-16	5-11-18	8-13-20	10-15-21	11-16-23	13-17-24	14-18-26	16-20-28	18-21-30	
12 x 12	Total Pressure (in. w.g.)	.024	.043	.067	.097	.131	.172	.217	.268	.386	.525	
	Flow Rate (cfm)	300	400	500	600	700	800	900	1000	1200	1400	
	Sound (NC)	-	23	30	35	40	44	48	51	57	61	
	Throw (ft.)	4 Way	3-6-13	5-9-15	8-11-17	9-13-19	11-14-20	12-15-22	13-16-23	14-17-24	15-19-26	16-20-29
	1 Way	3-8-16	6-11-18	9-14-20	11-16-22	13-17-24	15-18-26	16-19-27	17-20-29	18-22-32	20-24-34	
14 Ø	Total Pressure (in. w.g.)	.025	.045	.070	.101	.137	.180	.227	.281	.404	.550	
	Flow Rate (cfm)	321	428	535	641	748	855	962	1069	1283	1497	
	Sound (NC)	-	24	30	36	41	45	49	52	57	62	
	Throw (ft.)	4 Way	3-6-14	5-9-16	7-12-18	9-14-19	11-15-21	12-16-22	14-17-24	14-18-25	16-19-27	17-21-30
	1 Way	3-7-16	6-11-19	9-14-21	11-16-23	13-18-25	15-19-27	16-20-28	17-21-30	19-23-33	20-25-35	
14 x 14	Total Pressure (in. w.g.)	.029	.052	.081	.117	.159	.207	.263	.324	.467	.635	
	Flow Rate (cfm)	408	544	681	817	953	1089	1225	1361	1633	1905	
	Sound (NC)	17	26	33	39	44	48	51	55	60	65	
	Throw (ft.)	4 Way	4-9-15	8-12-18	10-14-20	12-15-22	14-17-24	15-18-25	15-19-27	16-20-28	18-22-31	19-24-33
	1 Way	5-11-19	9-14-21	12-17-24	14-19-26	16-20-28	17-21-30	19-23-32	20-24-34	21-26-37	23-28-40	
15 Ø	Total Pressure (in. w.g.)	.028	.050	.078	.112	.153	.200	.252	.312	.449	.611	
	Flow Rate (cfm)	368	491	614	736	859	982	1104	1227	1472	1718	
	Sound (NC)	16	25	32	38	42	46	50	53	59	64	
	Throw (ft.)	4 Way	3-7-15	6-10-17	9-13-19	10-15-21	12-16-22	14-17-24	15-18-25	15-19-27	17-21-29	18-22-32
	1 Way	4-8-18	7-12-20	10-15-23	12-18-25	14-19-27	16-20-29	18-22-30	19-23-32	20-25-35	22-27-38	

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Airflow is in cfm.
3. All pressures are in in. w.g.
4. Throw values are measured in feet for terminal velocities of 150 fpm (minimum), 100 fpm (middle), and 50 fpm (maximum).
5. Throw data is based on supply air and room air being at isothermal conditions.
6. NC, sound pressure levels, are based on room absorption of 10 dB re 10⁻¹² Watts and one diffuser.
7. Blanks (-) indicate an NC level below 15.
8. Data does not include effects of ceiling radiation damper (PDF-FR, PDFE-FR).