



UNIT SIZE	INLET SIZES		WIDTH W	HEIGHT H	LENGTH				
	D				A	B	L		
4	3 7/8 (98)		12 (305)	8 (203)	6 3/8 (162)	3 13/16 (97)	15 3/4 (400)		
5	4 7/8 (124)								
6	5 7/8 (149)								
7	6 7/8 (175)								
8	7 7/8 (200)								
9	8 7/8 (225)		14 (356)	12 1/2 (318)	4 3/8 (111)	3 13/16 (97)	15 3/4 (400)		
10	9 7/8 (251)								
12	11 7/8 (302)								
14	13 7/8 (352)		20 (508)	17 1/2 (445)				5 5/16 (135)	19 1/4 (489)
16	15 7/8 (403)			24 (610)					
24 x 16	23 7/8 (603) x 15 7/8 (403)		38 (965)	18 (457)	3 1/2 (89)	2 3/4 (70)	15 1/2 (394)		

STANDARD CONSTRUCTION:

- 1/2" (13mm) THICK INTERNAL FIBERGLASS INSULATION WHICH MEETS REQUIREMENTS OF NFPA 90A AND UL181.
- 22 GAUGE GALVANIZED STEEL HOUSING. MECHANICALLY SEALED, LEAK RESISTANT CONSTRUCTION.
- RECTANGULAR DISCHARGE OPENING WITH SLIP AND DRIVE CLEAT DUCT CONNECTION.
- MULTI-POINT, CENTER AVERAGING AIRFLOW SENSOR.
- 1/2" (13mm) GALVANIZED DAMPER SHAFT WITH POSITION INDICATOR.
- LEFT HAND UNIT SHOWN (CLH), RIGHT HAND AVAILABLE.

CONTROLS OPTIONS:

- FIELD MOUNTED CONTROLS, SUPPLIED BY OTHERS (FLD)
- FACTORY MOUNTED DIGITAL CONTROLS, SUPPLIED BY OTHERS (FAC)

CONTROLS SUPPLIED AND MOUNTED BY PRICE (EHP):

- DIGITAL CONTROLS (DIG)
- PNEUMATIC CONTROLS (PNEU)

UNIT OPTIONS:

- NEMA1 CONTROLS ENCLOSURE (PS)
- DISCONNECT SWITCH (DSW)
- 20 GAUGE CASING (20GA)
- HANGER BRACKETS (HB)
- BOTTOM REMOVABLE SENSOR (RS)
- BRASS AIRFLOW SENSOR GAUGE TAPS (GT)

BOTTOM ACCESS DOOR:

- ACCESS DOOR WITH SCREWS (AD)
- ACCESS DOOR WITH SNAP LATCHES (ADL)
- ACCESS DOOR WITH QUARTER TURN LATCHES (ADQ)

LINER OPTIONS:

- FIBERGLASS 1" (25mm) (FG1)
- FIBER FREE FOAM 1/2" (13mm) (FF50)
- FIBER FREE FOAM 3/4" (19mm) (FF75)
- FIBER FREE FOAM 1" (25mm) (FF1)
- FOIL FACED FIBERGLASS BOARD 1" (25mm) (FB1)
- SOLID METAL WITH FG1 (SM1)
- CLEANROOM ANGLES WITH FB1 (CRAF1)
- PERFORATED METAL WITH FB1 (AFPM1)



ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.

PROJECT:		<p>SDV SINGLE DUCT TERMINAL VARIABLE VOLUME</p>
ENGINEER:		
CUSTOMER:		
SUBMITTAL DATE:		
SPEC. SYMBOL:		<p>4</p> <p>269693</p> <p>04/05/2021</p>